

Watervliet High School Water Outlet Lead Testing

Testing Date: 10/28/2020

Results back 11/6/2021

| Sample ID | Location | Primary Test Result | Re-Test Result |
|------------------|-----------------------------|---------------------|----------------|
| 1ST FLOOR | | | |
| HS-0001 | KITCHEN PREP SINK | ND | |
| HS-0002 | 3 BAY SINK | ND | |
| HS-0003 | 3 BAY SINK SPRAYER | ND | |
| HS-0004 | DISHWASHER SPAYER | 1.8 | |
| HS-0005 | KITCHEN PREP SINK | ND | |
| HS-0006 | CAFÉ HALLWAY FOUNTAIN | ND | |
| HS-0007 | MENS FACULTY FOUNTAIN | ND | |
| HS-0008 | NURSES BR SINK | ND | |
| HS-0009 | NURSES SINK | ND | |
| HS-0010 | WOMENS FACULTY FOUNTAIN | ND | |
| HS-0011 | NEW WING BR FOUNTAIN | ND | |
| HS-0012 | NEW WING BR FOUNTAIN | ND | |
| HS-0030 | RM 123 SINK 1 | Laboratory | |
| HS-0031 | RM 123 SINK 2 | Laboratory | |
| HS-0032 | RM 123 SINK 3 | Laboratory | |
| HS-0033 | RM 123 SINK 4 | Laboratory | |
| HS-0034 | RM 123 SINK 5 | Laboratory | |
| HS-0035 | RM 123 CLOSET SINK | Laboratory | |
| HS-0036 | RM 124 SINK 1 | Laboratory | |
| HS-0037 | RM 124 SINK 2 | Laboratory | |
| HS-0038 | RM 124 SINK 3 | Laboratory | |
| HS-0039 | RM 124 SINK 4 | Laboratory | |
| HS-0040 | RM 121 SINK | Technology | |
| HS-0041 | GIRLS NEW WING BR SINK 1 | 1 | |
| HS-0042 | GIRLS NEW WING BR SINK 2 | ND | |
| HS-0043 | GIRLS NEW WING BR SINK 3 | 1.2 | |
| HS-0044 | BOYS NEW WING BR SINK 1 | 1.9 | |
| HS-0045 | BOYS NEW WING BR SINK 2 | ND | |
| HS-0046 | BOYS NEW WING BR SINK 3 | 1.1 | |
| HS-0047 | SUPERINTENDANT BR SINK | ND | |
| HS-0048 | RM 117 SINK 1 | Technology | |
| HS-0049 | RM 117 SINK 2 | Technology | |
| HS-0050 | GIRLS BR MAIN HALL SINK 1 | 1.3 | |
| HS-0051 | GIRLS BR MAIN HALL SINK 2 | 3.3 | |
| HS-0052 | GIRLS BR MAIN HALL SINK 3 | 6.6 | |
| HS-0053 | GIRLS BY MAIN HALL SINK 4 | 1.6 | |
| HS-0054 | WOMENS FACULTY BR SINK | ND | |
| HS-0055 | AUDITORIUM BR LEFT BR SINK | 2.3 | |
| HS-0056 | AUDITORIUM BR RIGHT BR SINK | 2.9 | |
| HS-0057 | MENS FACULTY BR SINK | 1.7 | |
| HS-0058 | BOYS BR MAIN HALL SINK 1 | ND | |
| HS-0059 | BOYS BR MAIN HALL SINK 2 | ND | |
| HS-0060 | BOYS BR MAIN HALL SINK 3 | ND | |
| HS-0061 | BOYS BR MAIN HALL SINK 4 | NO SINK | |
| HS-0062 | TRANS GENDER BR SINK | ND | |
| HS-0063 | GIRLS BR CAFÉ HALL SINK 1 | ND | |
| HS-0064 | GIRLS BR CAFÉ HALL SINK 2 | ND | |
| HS-0065 | BOYS BR CAFÉ HALL SINK 1 | ND | |
| HS-0066 | BOYS BR CAFÉ HALL SINK 2 | ND | |

| Key | |
|-----|--------------------|
| | Testing Complete |
| | Testing Needed |
| | Above Action Level |

ND=None detected

| | | | |
|------------------|---------------------------------|------------|---------------------------------|
| HS-0067 | 1st fl former AD Office BR SINK | 92.8 | Don't use: Shut off permanently |
| 2ND FLOOR | | | |
| HS-0013 | BOYS BR FOUNTAIN | ND | |
| HS-0014 | GIRLS BR FOUNTAIN | ND | |
| HS-0015 | NEW WING BR FOUNTAIN | ND | |
| HS-0016 | NEW WING BR FOUNTAIN | ND | |
| HS-0068 | RM 208 SINK 1 | Art Room | |
| HS-0069 | RM 208 SINK 2 | Art Room | |
| HS-0070 | ART RM CLOSET SINK | Art Room | |
| HS-0071 | RM 210 SINK 1 | Art Room | |
| HS-0072 | RM 210 SINK 2 | Art Room | |
| HS-0073 | BOYS BR MAIN HALL SINK 1 | 1.5 | |
| HS-0074 | BOYS BR MAIN HALL SINK 2 | ND | |
| HS-0075 | BOYS BR MAIN HALL SINK 3 | HD | |
| HS-0076 | FACULTY BR SINK | ND | |
| HS-0077 | RM 213 BR SINK (Office) | 16 | Sign on sink: Do not drink |
| HS-0078 | GIRLS BR MAIN HALL SINK 1 | ND | |
| HS-0079 | GIRLS BR MAIN HALL SINK2 | ND | |
| HS-0080 | GIRLS BR MAIN HALL SINK 3 | 1.8 | |
| HS-0081 | GIRLS BR MAIN HALL SINK 4 | 1.1 | |
| HS-0082 | GIRLS BR NEW WING SINK 1 | 2 | |
| HS-0083 | GIRLS BR NEW WING SINK 2 | ND | |
| HS-0084 | GIRLS BR NEW WING SINK 3 | ND | |
| HS-0085 | BOYS BR NEW WING SINK 1 | ND | |
| HS-0086 | BOYS BR NEW WING SINK 2 | ND | |
| HS-0087 | BOYS BR NEW WING SINK 3 | ND | |
| HS-0088 | RM 220 SINK 1 | Laboratory | |
| HS-0089 | RM 220 SINK 2 | Laboratory | |
| HS-0090 | RM 220 SINK 3 | Laboratory | |
| HS-0091 | RM 220 SINK 4 | Laboratory | |
| HS-0092 | RM 220 SINK 5 | Laboratory | |
| HS-0093 | RM 220 SINK 6 | Laboratory | |
| HS-0094 | RM 220 SINK 7 | Laboratory | |
| HS-0095 | RM 220 SINK 8 | Laboratory | |
| HS-0096 | RM 220 SINK 9 | Laboratory | |
| HS-0097 | RM 220 SINK 10 | Laboratory | |
| HS-0098 | RM 220 SINK 11 | Laboratory | |
| HS-0099 | RM 220 SINK 12 | Laboratory | |
| HS-0100 | RM 220 SINK 13 | Laboratory | |
| HS-0101 | RM 220 SINK 14 | Laboratory | |
| HS-0102 | RM 220 SINK 15 | Laboratory | |
| HS-0103 | RM 220 SINK 16 | Laboratory | |
| HS-0104 | RM 220 SINK 17 | Laboratory | |
| HS-0105 | CLOSET IN 220 SINK 1 | Laboratory | |
| HS-0106 | CLOSET IN 220 SINK 2 | Laboratory | |
| HS-0107 | CLOSET IN 220 SINK 3 | Laboratory | |
| HS-0108 | RM 222 SINK 1 | Laboratory | |
| HS-0109 | RM 222 SINK 2 | Laboratory | |
| HS-0110 | RM 222 SINK 3 | Laboratory | |
| HS-0111 | RM 222 SINK 4 | Laboratory | |

| | | | |
|------------------|----------------------------|---------------------------|-------------|
| HS-0112 | RM 222 SINK 5 | Laboratory | |
| HS-0113 | RM 222 SINK 6 | Laboratory | |
| HS-0114 | RM 222 SINK 7 | Laboratory | |
| HS-0115 | RM 222 SINK 8 | Laboratory | |
| HS-0116 | RM 223 SINK 1 | Laboratory | |
| HS-0117 | RM 223 SINK 2 | Laboratory | |
| HS-0118 | RM 223 SINK 3 | Laboratory | |
| HS-0119 | RM 223 SINK 4 | Laboratory | |
| HS-0120 | CLOSET IN 223 SINK | Laboratory | |
| HS-0121 | RM 224 SINK | Laboratory | |
| HS-0122 | RM 225 SINK 1 | Laboratory | |
| HS-0123 | RM 225 SINK 2 | Laboratory | |
| HS-0124 | CLOSET IN 225 SINK | Laboratory | |
| HS-0125 | RM 226 SINK | 2.3 | |
| 3RD FLOOR | | | |
| HS-0017 | BOYS BR FOUNTAIN | ND | |
| HS-0018 | HOME & CAREERS SINK | 1.1 | |
| HS-0019 | HOME & CAREERS SINK | 6.8 | |
| HS-0020 | HOME & CAREERS SINK | 1.8 | |
| HS-0021 | HOME & CAREERS SINK | 3.9 | |
| HS-0022 | WOMENS BR FOUNTAIN | Broken/NOT WORKING | NOT WORKING |
| HS-0126 | BOYS BR SINK 1 | 2 | |
| HS-0127 | BOYS BR SINK 2 | 2 | |
| HS-0128 | LIBRARY BR SINK | 1.5 | |
| HS-0129 | FACULTY BR SINK | 3.6 | |
| HS-0130 | GIRLS BR SINK 1 | 2.3 | |
| HS-0131 | GIRLS BR SINK 2 | 2.4 | |
| BASEMENT | | | |
| HS-0023 | WRESTLING HALLWAY FOUNTAIN | ND | |
| HS-0024 | GYM FOUNTAIN-left side | No Battery-NOT WORKING | retest |
| HS-0025 | GYM FOUNTAIN -left side | No Battery-NOT WORKING | retest |
| HS-0026 | GYM FOUNTAIN | ND | |
| HS-0027 | GYM FOUNTAIN | ND | |
| HS-0028 | ICE MACHINE | 3 | |
| HS-0029 | CONCNCESSION STAND SINK-L | 14.4 | |
| HS-0132 | BOYS LOCKER RM BR SINK 1 | 2.3 | |
| HS-0133 | BOYS LOCKER RM BR SINK 2 | 1.3 | |
| HS-134 | MEN COACHS RM SINK | 1.7 | |
| HS-0135 | MEN COACHS RM2 SINK | 1.7 | |
| HS-0136 | GIRLS LOCKER RM BR SINK 1 | 4.1 | |
| HS-0137 | GIRLS LOCKER RM BR SINK 2 | 3.7 | |
| HS-0138 | WOMENS COACHS OFF SINK | 1.4 | |
| HS-0139 | BOYS BR WRESTLING SINK | 3.5 | |
| HS-0140 | GIRLS BR WRESTLING SINK | 11.6 | |
| HS-0141 | GIRLS BR GYM SINK 1 | 1.4 | |
| HS-0142 | GIRLS BR GYM SINK 2 | 1.1 | |
| HS-0143 | GIRLS BR GYM SINK 3 | 3.4 | |
| HS-0144 | BOYS BR GYM SINK 1 | 2.2 | |
| HS-0145 | BOYS BR GYM SINK 2 | 3.6 | |

| | | | |
|---------|--------------------------|------|--|
| HS-0146 | BOYS BR GYM SINK 3 | 7.8 | |
| HS-0147 | FAMILY BR SINK | 5.9 | |
| HS-0148 | GIRLS BR FIELD SINK 1 | 12.6 | |
| HS-0149 | GIRLS BR FIELD SINK 2 | 11.9 | |
| HS-0150 | BOYS BR FIELD SINK 1 | 3 | |
| HS-0151 | BOYS BR FIELD SINK 2 | 2.1 | |
| HS-0152 | SPICKET CONCESSION STAND | ND | |
| HS-0153 | SPICKET NEW WING | ND | |
| HS-0154 | SPICKET RM 117 | ND | |
| HS-0155 | SPICKET AUDITORIUM | 2.8 | |

| | | | |
|------------|--------------------------------|------|--|
| X ROOM 105 | sink team room sub basement | ND | |
| x-01 | sink team room br sub basement | 6 | |
| x 02 | conesession sink R | 11.7 | |

